



NOTES:

1. All wiring must conform to National Electrical Safety Code and Municipal Code as required.
2. Municipal jurisdiction will require city inspection of loop before connection.
3. Notify Bartlett Electric Cooperative when breaker is installed.
4. Bartlett Electric Cooperative pole must remain free of structures and private attachments other than meter loop riser assembly.
5. Member furnishes and installs UG service wire and conduit from UJB to meter.
6. Electrical contractor will leave 5' tail at meter base so Cooperative can terminate in UJB and meter base.
7. Electrical contractor shall intercept conduit out of UJB.

FOR THE MEMBER'S SAFETY,
WIRING INSTALLATIONS SHALL
CONFORM TO THE REQUIREMENTS
OF THE NEC AND NESC.

Bartlett Electric Cooperative, Inc.
P.O. Box 200
Bartlett, Texas 76511

**SINGLE PHASE, 200AMP UNDERGROUND
SERVICE ON BUILDING FROM OVERHEAD
WITH CLASS 200AMP METER SOCKET**

Drawn By: TE, MEI	Checked By: -	Approved By: -	Revised by: AH
Scale: N.T.S.	Date: 08/26/14	Drawing #: BEC-MS-5	Date: 09/08/14